

Table 1
Lead in Water Analytical Results Summary
Huntington UFSD
Flower Hill Primary School

Sample Location	First Draw (Initial)	First Draw (Final)
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. Kitchen Sink	1.51	NS
2. Hallway-Cafeteria	1.05	NS
3. Room 16	ND	NS
4. Hallway-Room 17	3.43	NS
5. Room 17	1.11	NS
6. Room 20	4.94	NS
7. Room 21	3.33	NS
8. Room 22	4.20	NS
9. Hallway-Room 8	3.26	NS
10. Room 8	9.43	NS
11. Room 7	2.21	NS
12. Room 6	3.35	NS
13. Room 5	13.4	NS
14. Room 4	1.29	NS
15. Room 3	3.76	NS
16. Room 1	8.13	NS
17. Room 2	2.80	NS
18. Room 10	4.60	NS
19. Room 11	1.54	NS
20. Room 12	3.72	NS
21. Room 13	1.52	NS
22. Room 14	5.20	NS
23. Teachers' Lounge Sink	18.3	2.80

Notes:

ND = Not Detected NS = Not Sampled

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

Locations are water fountains unless otherwise specified.

Table 1
 Lead in Water Analytical Results Summary
 Huntington UFSD
 Jefferson Primary School

Sample Location	First Draw (Initial)	First Draw (Final)
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. Hallway by Room 9	20.7	13.0
2. Room 7	12.4	NS
3. Room 8	4.69	NS
4. Room 6	5.80	NS
5. Room 5	6.59	NS
6. Room 4	2.12	NS
7. Room 3	2.22	NS
8. Room 1	4.40	NS
9. Room 2	5.35	NS
10. Room 14	7.06	NS
11. Hall by Library	15.8	12.0
12. Room 17	8.03	NS
13. Room 19	4.69	NS
14. Room 18	3.93	NS
15. Room 21	6.40	NS
16. Room 20	5.89	NS
17. Room 23	6.90	NS
18. Room 22	10.6	NS
19. Hall by Room 24	11.3	NS
20. Room 24	8.86	NS
21. Room 25	7.56	NS
22. Room 26	2.19	NS
23. Room 27	3.50	NS
24. Hall by Lunch Room	1.64	NS
25. Hall by Gym	3.52	NS
26. Kitchen Sink	5.66	NS

Notes:

ND = Not Detected NS = Not Sampled

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

Locations are water fountains unless otherwise specified.

Table 1
Lead in Water Analytical Results Summary
Huntington UFSD
Southdown Primary School

Sample Location	First Draw (Initial)
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>	
1. Kitchen Sink	3.50
2. Hallway-Gym	2.45
3. Room 16	2.34
4. Hallway-Room 17	4.70
5. Room 17	3.06
6. Room 18	2.28
7. Room 19	3.31
8. Room 22	3.39
9. Room 21	2.38
10. Faculty Lounge Sink	9.18
11. Room 5	2.54
12. Room 4	5.05
13. Room 3	1.59
14. Room 1	1.28
15. Room 2	6.05
16. Hallway-Conference Room	1.69
17. Room 7	1.81
18. Room 8	4.88
19. Room 9	1.49
20. Room 10	2.24
21. Room 11	1.42
22. Room 12	1.53
23. Room 13	1.16
24. Room 14	2.76

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

Locations are water fountains unless otherwise specified.

Table 1
 Lead in Water Analytical Results Summary
 Huntington UFSD
 Washington Primary School

Sample Location	First Draw (Initial)
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>	
1. Hallway At Cafeteria	ND
2. Hallway-Room 17	ND
3. Room 21	ND
4. Room 19	1.55
5. Room 18	3.08
6. Room 17	2.98
7. Room 16	1.20
8. Hallway-Room 8	ND
9. Room 8	ND
10. Room 7	ND
11. Room 6	ND
12. Room 5	ND
13. Room 4	ND
14. Room 3	ND
15. Room 1	ND
16. Room 10	1.85
17. Room 11	1.50
18. Room 12	ND
19. Room 13	2.42
20. Room 14	ND
21. Kitchen Sink 1	10.8

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

Locations are water fountains unless otherwise specified.

Table 1
Lead in Water Analytical Results Summary
Huntington UFSD
Woodhull Intermediate School

Sample Location	First Draw (Initial)	First Draw (Final)
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. Faculty Lounge	1.36	NS
2. Hall by Room 12	2.82	NS
3. Room 12	3.85	NS
4. Room 5	1.34	NS
5. Room 7	4.70	NS
6. Room 8	4.83	NS
7. Room 11	16.5	6.7
8. Room 10	51.3	9.2
9. Room 24	14.8	NS
10. Room 22	14.5	NS
11. Room 25	4.15	NS
12. Room 21	4.96	NS
13. Room 20	4.88	NS
14. Room 26	4.80	NS
15. Hall by Room 26	3.29	NS
16. Room 19	71.9	1.30
17. Room 18	8.42	NS
18. Room 17	1.89	NS
19. Room 16	6.23	NS
20. Hall by Room 15	ND	NS
21. Room 15	1.29	NS
22. Principal's Office	7.17	NS
23. Hall by Boiler Room	17.7	9.10
24. Main Office Meeting Area	14.2	NS
25. Kitchen Sink	2.43	NS

Notes:

ND = Not Detected NS = Not Sampled

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

Locations are water fountains unless otherwise specified.

Table 1
 Lead in Water Analytical Results Summary
 Huntington UFSD
 Jack Abrams STEM Magnet School

Sample Location	First Draw (Initial)	First Draw (Final)
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. Cafeteria	ND	NS
2. Room 213	13.8	NS
3. Room 215	7.39	NS
4. Room 214	4.77	NS
5. Room 217	26.7	11.0
6. Room 216	6.93	NS
7. Room 218	4.05	NS
8. Room 219	10.2	NS
9. Room 220	8.30	NS
10. Room 221	6.34	NS
11. by Gym Door C	ND	NS
12. Hall by Main Office	1.78	NS
13. Hall by Room 122	4.00	NS
14. 1 st Floor Hall by Men's Bathroom	5.43	NS
15. Room 211	11.3	NS
16. Room 209	32.9	9.40
17. Room 210	7.12	NS
18. Room 208	7.70	NS
19. Room 207	21.3	9.30
20. Room 206	10.3	NS
21. Room 205	22.0	14.0
22. Room 204	50.7	12.0
23. Room 203	43.8	12.0
24. Room 202	32.9	5.80
25. Room 201	41.6	6.53
26. Kitchen Pot Filler 1	15.0	8.60
27. Kitchen Pot Filler 2	41.0	4.50
29. Kitchen Sprayer	37.0	8.80

Notes:

ND = Not Detected NS = Not Sampled

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

Locations are water fountains unless otherwise specified.

Table 1
 Lead in Water Analytical Results Summary
 Huntington UFSD
 J. Taylor Finley Middle School

Sample Location	First Draw (Initial)
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>	
1. Hallway-Custodial Office	ND
2. Kitchen Sink	3.51
3. Hallway-Boys Gym Office	1.75
4. Hallway-Auditorium	5.51
5. Hallway-Room 115	3.30
6. Hallway-Room 122	3.55
7. Hallway-Main Office	3.86
8. Hallway-Room 105	ND
9. Hallway-Room 107	4.42
10. Hallway-Main Lobby	ND
11. Hallway-Room 203	2.29
12. Hallway-Room 224A	ND
13. Hallway-Room 218	2.34
14. Hallway-Room 210	3.23
15. Hallway-Room 207	3.05
16. Hallway-Girls Gym	3.56

Notes:

ND = Not Detected

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

Locations are water fountains unless otherwise specified.

Table 1
Lead in Water Analytical Results Summary
Huntington UFSD
Huntington High School

Sample Location	First Draw (Initial)	First Draw (Final)
<i>Lead (in micrograms per liter (ug/L) or ppb)</i>		
1. Boiler Hallway	3.03	NS
2. Building & Grounds Hallway	ND	NS
3. Hallway-Door to Courtyard	5.74	NS
4. Hallway-Room 112	5.23	NS
5. Faculty Room	1.08	NS
6. Cafeteria "A"	6.29	NS
7. Cafeteria "B"	ND	NS
8. Hallway-Room 105	3.85	NS
9. Hallway-Room 103	1.62	NS
10. Hallway-Room 107	1.53	NS
11. Hallway-Room 109	1.02	NS
12. Hallway-Room 110	4.50	NS
13. Hallway-Room 150	9.44	NS
14. Hallway-Room 141	5.44	NS
15. Hallway-Room 132*	15.6	15.0
16. Hallway-Room 123	6.06	NS
17. Four Corners	ND	NS
18. Gym Lobby	ND	NS
19. Hallway-Room 263	1.56	NS
20. Hallway-Room 202	ND	NS
21. Hallway-Room 203	3.32	NS
22. Hallway-Room 208	3.77	NS
23. 2 nd Floor Ramp	ND	NS
24. Hallway-Room 251	8.02	NS
25. Hallway-Room 241	3.97	NS
26. Hallway-Room 228	4.96	NS
27. Hallway-Room 219	1.37	NS

Notes:

ND = Not Detected NS = Not Sampled

Action Level = 15.0 parts per billion (ppb) (ug/L)

Shaded values indicate an exceedance of the 15.0 ppb Action Level

Locations are water fountains unless otherwise specified.

* Taken off-line